



# 000301 Lobbies and Vestibules

## TYPICAL BUILDING SPACES

### 1 General

All building entrances shall have a vestibule at least 10'-0" in length with an appropriate slip-resistant and durable floor covering serving as a walk off mat. Entry door sequencing shall have auto operators and card key readers for after-hour use. Knox box locations shall be coordinated with the Fire Department. Building lobbies or attended reception areas are not necessarily required and will be determined by the user group and programming needs. The doors shall be single or double doors according to design needs. Auto operators shall be installed both in and out of the vestibule for ease of access. A recessed and removable walk-off mat is preferred.

### 2 Sample Layout



