



Division 238400

Humidity Control Equipment

DESIGN GUIDE

1 General

1.1 General

- A. Generally, the campus does not have building humidification unless dictated by process/equipment in the space.
- B. The campus steam system chemical treatment is not compatible with direct injection steam humidification.
- C. Provide indirect steam-to-steam humidifiers when humidification is required and campus steam is available.

2 Materials

2.1 Reserved for future content.

3 Execution

3.1 Reserved for future content.



4 Appendix

4.1 Reserved for future content.