

2016 BIENNIAL FIRE INSPECTION SUMMARY









ACADEMIC & BUSINESS BUILDINGS

9	Wedged Open Fire Doors
8	Emergency Fire Doors Failed to Close & Latch
8	Use of Extension Cords as Permanent Wiring
6	Daisy Chaining of Power Taps (Surge Protectors)
4	EXIT Signs - Battery Mode Failed
3	Inspect Annually All Fire Sprinkler Systems / Standpipe Systems
3	Test & Label Emergency Communication System (Areas of Refuge)
3	Replace Out-Dated Self Illuminated EXIT Signs (Tritium)
3	Emergency Lighting Did Not Operate
3	Secure Compressed Gas Cylinders
2	Remove Thumb Locks from Egress Doors
2	Remove Fold Down Feet on Fire Doors
2	Open Holes in Walls - Repair/Seal
2	<18-inches Storage - Blocking Fire Sprinklers
2	No Cover on Junction Electrical Boxes
2	Confirm Fire Ratings of Curtains
2	Unapproved (non-UL) Power Taps (Surge Protectors)
2	Fire Extinguisher Overdue for Annual Inspection
2	Test & Label All Roll-up Fire Doors
1	Propped Open Fire Doors
1	Portable Electric Heaters Not Plugged into Permanent Electrical Outlet (Wall Outlet)
1	Confirm Flammable Inventory Does Not Exceed Permitted Quantities
1	Defeating Latching Mechanism on Fire Door
1	Stored Combustible Items Underneath Stairwells
1	Provide one (1) 2A10BC (5 lbs.) Fire Extinguisher Every 3000 sq. ft.
1	Provide "Wire Bridge" for Flexible Wiring
1	Aisle / Egress Width Narrowed by Stored Items
1	Blocked Electrical Panels

Campus-wide universal recommendations; three (3) or more instances noted in building(s) indicated as problematic overall (campus as a whole)



2016 BIENNIAL FIRE INSPECTION SUMMARY

	
<p>Fire doors cannot be wedged or have attachments (fold down foot) to keep doors open</p>	
	
<p>Daisy-chaining or extension cords plugged into power taps (surge protectors) are prohibited</p>	
	
<p>Battery back-up failed to illuminate EXIT</p>	<p>Self-illuminating EXIT signs have expired</p>
	
<p>Fire sprinkler & standpipe systems overdue for annual inspection</p>	<p>Annually test & confirm emergency phones perform as intended</p>